



West Metro Fire Protection District

Life Safety Division

Technical Bulletin

Subject:	<i>Painted or Dyed Fire Alarm Wiring</i>		
Code/Standard:	<i>NFPA 70, 72</i>	Bulletin No:	2022-004
Bulletin Type:	<input checked="" type="checkbox"/> <i>Fire Code Interpretation</i>	Effective Date:	<i>9/1/2022</i>
	<input type="checkbox"/> <i>West Metro Fire Protection District Policy</i>	Approved By:	<i>K Brooks</i>

Scope/Purpose:

To set forth acceptable conditions for the use and installation of painted or dyed fire alarm system wire within the West Metro Fire Protection District.

Requirement(s):

Painted or dyed fire alarm wiring will not be accepted in new fire alarm system installations.

Exceptions:

1. Spooled or re-spooled fire wire that has been dyed and inspected and approved by Underwriters Laboratory or other qualified testing laboratory or agency and approved by the West Metro Fire Protection District.
 2. Painted fire wire is acceptable and may be installed only if the manufacturer of the wire has provided a letter or other form of approval that the paint type and method of application is acceptable. This letter must be on site and available for review during installation and shall be maintained with the records for the building fire alarm system.
-

Reference(s):

None

Attachments:

None